

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7271-1062:115 Page 1 of 1

**CATEGORY:** Ionization Smoke Detector

**LISTEE:** Detection Systems, Inc., 130 Perinton Parkway, Fairport, NY 14450  
Contact: Frank Mioduszewski (585) 223-4060 Fax (585) 421-4263

**DESIGN:** Model DS260 ionization type smoke detector. Refer to listee's printed data sheet for additional detailed product description and operational considerations.

**RATING:** 10-30 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as ionization smoke detector for use with separately listed compatible fire alarm control units. Unit is intended for use with Models MB2W, MB2WL, MB4W, MB4WA, MB4WS or MB4WE bases (CSFM Listing No. 7300-1062:107) or Duct Detector Housing Model \*DS290 (CSFM Listing No. 3240-1062:136) or Models DS291 or DS292 (CSFM Listing No. 3240-1062:134). Refer to listee's Installation Instruction Manual for details.

\*Rev. 12-22-2002KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **DECEMBER 22, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager